

CITY OF HALLANDALE BEACH, FLORIDA ATTACHMENT 4
MEMORANDUM

DATE: July 9, 2008
TO: Christy Dominguez, Director of Planning & Zoning
FROM: Daniel Sullivan, ~~Director, Department of Fire Rescue~~
SUBJECT: RENEWAL OF NIGHTCLUB LICENSES FOR FY 2008/2009

Fire staff conducted fire safety inspections of the Nightclubs referenced in Christy Dominguez memo of June 26, 2008. The inspections revealed no significant threat to occupant safety and staff has no objections to their license renewals to the following Occupancies:

- Flanigan's Seafood Bar & Grill 4 N. Federal Highway. 6:00 Closing.
- Gufstream Park Food & Beverage 901 S. Federal Highway 6:00 Closing
- Hollywood Concessions, Inc 831 N. Federal Highway. 6:00 Closing
- Ocean's II Lounge South 800 N. federal Highway. 6:00 Closing

However, the following two occupancies have significant life safety violations. At this time, Fire Staff can not recommend their license be renewed until all violations have been corrected.

- Fl Tatiana Club-Restaurant, Inc 1710 E. Hallandale Beach Blvd.
- The Wine Cellar Restaurant 1727 E. Hallandale Beach Blvd.

If you need further information please contact me at extension 1479.

Prepared by: _____


Miguel Aleman, Fire Marshal

City of Hallandale Beach
Fire Prevention Bureau
121 South West 3 Street
Hallandale Beach, Florida 33009
PH. (954)457-1477 FAX

Business Name: Tatiana s
Property Address: 1710 E Hallandale Beach Blvd
Hallandale Beach, Fl 33009
Location: 838,854
Date: 7/3/2008
Inspection Type: Annual

Fire Code Violations

Violation Number: 1
Violation Type: Exit light battery backup failed.
Violation Location:
Compliance Remedy: Check bulbs and batteries for fault and replace.

Violation Number: 2
Violation Type: Emergency lights not working when tested.
Violation Location:
Compliance Remedy: Check bulbs and batteries for fault and replace.

Violation Number: 3
Violation Type: Exit sign bulbs are not working.
Violation Location: mens restroom
Compliance Remedy: Check bulbs and batteries for fault and replace.

Violation Number: 4
Violation Type: Business is using extension cords/adaptors.
Violation Location: kitchen / bar
Compliance Remedy: Remove extension cords/adaptors, use proper electric.

Violation Number: 5
Violation Type: Other
Violation Location: fire rating on curtains
Compliance Remedy: .

Charles Hackett
Inspector

VIOLATIONS SHALL BE CORRECTED IMMEDIATELY

Business Name: Tatiana s
Property Address: 1710 E Hallandale Beach Blvd
Hallandale Beach, Fl 33009
Location: 838,854
Date: 7/3/2008

Inspection Type: Annual

Fire Code Violations

Violation Number: 6
Violation Type: Exits are locked.
Violation Location: master lock on rear exit in kitchen
Compliance Remedy: All exits must remain unlocked during business hours.

Violation Number: 7
Violation Type: Cylinders are not secured/cap missing.
Violation Location: CO2 tanks need to be secured
Compliance Remedy: Secure cylinders and or replace missing caps.

Violation Number: 8
Violation Type: Fire extinguisher must be wall mounted.
Violation Location:
Compliance Remedy: Mount fire extinguisher on wall.

Violation Number: 9
Violation Type: Exits are locked.
Violation Location: doors leading to exit are locked
Compliance Remedy: All exits must remain unlocked during business hours.

Violation Number: 10
Violation Type: Exitways are obstructed.
Violation Location: 36" clearance
Compliance Remedy: Must maintain 36 inch aisles to exits at all times.

Violation Number: 11
Violation Type: Business is using extension cords/adaptors.
Violation Location: to trees outside
Compliance Remedy: Remove extension cords/adaptors, use proper electric.

Violation Number: 12
Violation Type: Fire dept. connection is missing covers.
Violation Location:
Compliance Remedy: Replace missing covers.

Charles Hackett
Inspector

VIOLATIONS SHALL BE CORRECTED IMMEDIATELY

Business Name: Tatiana s
Property Address: 1710 E Hallandale Beach Blvd
Hallandale Beach, Fl 33009
Location: 838,854
Date: 7/3/2008

Inspection Type: Annual

Fire Code Violations

Violation Number: 13
Violation Type: Fire dept. connection sign is missing outside.
Violation Location:
Compliance Remedy: Replace missing sign "Fire Department Connection".

Violation Number: 14
Violation Type: Fire dept. connection is blocked or not visible.
Violation Location: remove debris
Compliance Remedy: Make connection accessible to the fire dept.

Violation Number: 15
Violation Type: Other.
Violation Location: fire system - kitchen
Compliance Remedy: .

Charles Hackett
Inspector

VIOLATIONS SHALL BE CORRECTED IMMEDIATELY

City of Hallandale Beach
Fire Prevention Bureau
121 South West 3 Street
Hallandale Beach, Florida 33009
PH. (954)457-1477 FAX

Business Name: THE WINE CELLAR
Property Address: 1727 E HALLANDALE BEACH BLVD
Hallandale Beach, Fl 33009
Location: 838,068
Date: 7/8/2008
Inspection Type: Annual

Fire Code Violations

Violation Number: 1
Violation Type: Maximum capacity sign missing.
Violation Location: OUTDOOR SEATING
Compliance Remedy: Post maximum capacity sign in clear view of patrons.

Violation Number: 2
Violation Type: Special Hazards Category.
Violation Location: REAR EXIT NOT APPROVED - DOOR PERMIT STILL OPEN
Compliance Remedy: ,

Violation Number: 3
Violation Type: Hood system overdue for service.
Violation Location: LAST TAG 9/07
Compliance Remedy: System must be serviced and tagged on a six month basis.

Violation Number: 4
Violation Type: Extinguishers overdue for service.
Violation Location: EXTINGUISHERS DUE END OF JULY
Compliance Remedy: Have extinguishers serviced immediately.

Violation Number: 5
Violation Type: Exitways are obstructed.
Violation Location: EXIT FROM KITCHEN INTO PRIVATE DINING AREA
Compliance Remedy: Must maintain 36 inch aisles to exits at all times.

Lori Williams
Inspector

VIOLATIONS SHALL BE CORRECTED IMMEDIATELY

Business Name: THE WINE CELLAR
Property Address: 1727 E HALLANDALE BEACH BLVD
Hallandale Beach, FL 33009
Location: 838,068
Date: 7/8/2008

Inspection Type: Annual

Fire Code Violations

Violation Number: 6
Violation Type: Other
Violation Location: HANDLE NOT WORKING FOR CLOSET COOLER
Compliance Remedy: .

Violation Number: 7
Violation Type: Fire alarm system needs service.
Violation Location: REAR HORN STROBE BROKEN AT EXIT DOOR
Compliance Remedy: Service fire alarm system immediately.

Violation Number: 8
Violation Type: Other.
Violation Location: REPLACE ALL MISSING SPRINKLER ESCUTCHEON PLATES
Compliance Remedy: .

Violation Number: 9
Violation Type: Other.
Violation Location: CONFIRM SPRINKLERS IN CLOSET COOLER ARE PROPER TYPE AND COVERAGE ABOVE
Compliance Remedy: .

Violation Number: 10
Violation Type: Exitways are obstructed.
Violation Location: REAR EXIT DOOR FROM KITCHEN BLOCKED BY PARKING
Compliance Remedy: Must maintain 36 inch aisles to exits at all times.

Lori Williams
Inspector

VIOLATIONS SHALL BE CORRECTED IMMEDIATELY