

**DEVELOPMENT SERVICES- BUILDING DIVISION  
NIGHTCLUB INSPECTIONS REPORT  
FY 2008-2009**

DATE/TIME	LOCATION/ADDRESS	RESULT	COMMENTS
07/13/2009-10:30A-11:00A	FL TATIANA CLUB-RESTAURANT, INC 1710 E. HALLANDALE BEACH BLVD	Approved	
07/13/2009-11:30A-12:00P	FLANNIGAN'S SEAFOOD BAR AND GRILL 4. N. FEDERAL HIGHWAY	Failed	1.) Emergency light in women's bathroom failed to operate. Double check all emergency lights for operation
07/16/2009-11:00A-11:30A	FLANNIGAN'S SEAFOOD BAR AND GRILL 4. N. FEDERAL HIGHWAY	Approved	<del>1.) Emergency light in women's bathroom failed to operate. Double check all emergency lights for operation.</del>
07/13/2009-12:00P-12:30P	GULFSTREAM PARK FOOD & BEVERAGE 901 S. FEDERAL HIGHWAY	Approved	
07/13/2009-1:00P-1:30P	HOLLYWOOD CONCESSIONS, INC 831 N. FEDERAL HIGHWAY	Approved	
07/13/2009-1:30P-1:30P	OCEAN'S 11 LOUNGE SOUTH 800 N. FEDERAL HIGHWAY	Approved	
07/13/09-11:00A-11:30A	CHAPULTEPEC MEXICAN BAR & RESTAURANT 23 N.W. 2ND AVENUE	Failed	1.) Womens bathroom emergency light does not work
07/16/09-11:30A-12:00P	CHAPULTEPEC MEXICAN BAR & RESTAURANT 23 N.W. 2ND AVENUE	Approved	<del>1.) Womens bathroom emergency light does not work.</del>