

Application : 13 00002881
Address : 901 S FEDERAL HWY
Application type : COMMERCIAL, BUILDING OTHER '08
Revision/Path/Step/Seq/Agency: * 00 00 ROUT ROUTE PERMIT APPLICATION

Type	Date	Description
OUT	9/13/13	N/A/SENT TO REV/SHELF...GCR
IN	9/12/13	RCC APP TO REVIEW SHELF
OUT	9/12/13	REJ TO ZONING /RPS
IN	9/12/13	IN PLB RPS
OUT	9/11/13	REJ//SENT TO PLUMB DESK...ALP
IN	9/10/13	REJ TO REV SH RHA
OUT	9/09/13	PLANS IN TO REV SLF..EL

} 1ST ROUND
4 DAYS

Bottom

Press Enter to continue.
F3=Exit F12=Cancel F14=Action log inq

Application : 13 00002881
Address : 901 S FEDERAL HWY
Application type : COMMERCIAL, BUILDING OTHER '08
Revision/Path/Step/Seq/Agency: * 00 00 ROUT ROUTE PERMIT APPLICATION

Type	Date	Description
OUT	9/25/13	APP TO APP SH RHA
IN	9/25/13	PLANS IN TO REV SLF..EL
OUT	9/24/13	REJ LTR SNT>REJ SHLF GCH
IN	9/24/13	NA TO REJ SHELF/RPS
OUT	9/24/13	IN PLB RPS
IN	9/23/13	REJ TO REV SH RHA
OUT	9/23/13	MECH. N/A >TO REV SHELF/GCR
IN	9/20/13	ELEC NA BACK TO EXP SHELF/CS
OUT	9/20/13	ELECTRICAL 2ND REVIEW //CS
IN	9/20/13	RCC APP TO REVIEW SHELF
OUT	9/19/13	PLNS IN 2 REV SHLF..LR

} 3rd ROUND BUILDING ONLY
 < 1 DAY

} 2nd ROUND
 3 DAYS

More...

Press Enter to continue.
F3=Exit F12=Cancel F14=Action log inq

APP NBR 13 00002881 ADDRESS 901 S FEDERAL HWY 1227-01-0190
 Follo number 514227010190
 APPLICATION TYPE COMMERCIAL, BUILDING OTHER '08 APP DATE 9/09/13 OCC TYP N/A VALUATION 1810906
 COUNTY FOLIO# 514227010190

AGENCY REV BY ACTION DATE TIME DAYS
 BUILDING RND 1 RHA REJECTED 9/10/13 .00 0
 COMMENTS: Closed by revision 001 LROBERTS GML1110

COMMENTS: Plans to be signed and sealed (original). Plans to be at scale showing construction details at scale. Information on accessible baths required. Floor plans showing dimensions, vertical accessibility, etc. are required.
 Maximum travel distance 100' for temporary structure. 3103.4
 Elevation showing membrane and exits required. Information for spaces from 1 to 12 adjacent to the horse walk is required.
 All references in structural notes to be to FBC 10. Details for horses stall are required.
 Provide Special Inspector form signed and sealed by a PE, and signed by owner and contractor.
 Occupancy use to be U. FBC 10 312
 Membrane fabric must meet FPFC. Provide information on that issue.

BUILDING RND 2 RHA REJECTED 9/23/13 .00 13
 COMMENTS: Closed by revision 008 ELMONHARDT POL9999

COMMENTS: Building is open on 4 sides with fabric stop at 12' from the ground. On wind design data the GCP1 0.18 is for enclosed building. Please, clarify.
 Geotechnical report required.
 based on use and area this building is type IA FBC10 503

BUILDING RND 3 RHA APPROVED 9/25/13 1.50 2
 COMMENTS: This permit is only for the structural part of this project

AGENCY TOTALS: 3.25 15
 ELECTRICAL INSPECTOR ### REJECTED 9/11/13 .00 0
 COMMENTS: Closed by revision 003 LROBERTS GML1110

ELECTRICAL INSPECTOR RND 1 ALP REJECTED 9/11/13 1.00 0

APP NBR ADDRESS
 Folio number

APPLICATION TYPE
 COUNTY FOLIO#

APP DATE OCC TYP VALUATION

COMMENTS:
 1. SHEET #1 SHOWS EXIT LIGHTS AT VARIOUS LOCATIONS IN THE TEMP. BARN, PLEASE SHOW WHERE THE POWER FOR THESE LIGHTS DERIVE FROM. ALSO THE SERVICE EQUIPMENT AND LOCATION FOR THE TEMP BARNS...FBC 107.7.B.4
 2. SHEET #1 SHOWS TEMP RESTROOMS, PLEASE SHOW THE POWER REQUIREMENTS FOR THOSE RESTROOMS...FBC 107.7.B.4
 3. WILL THERE BE ANY GENERAL LIGHTING IN THESE TEMP BARNS? IF SO, PLEASE SHOW THE ELECTRICAL REQUIREMENTS...
 4. PLEASE SHOW THE ROUTING AND LOCATION OF POWER FEED CONDUIT AND EQUIPMENT RELATED TO THE NEW LIFT STATION... FBC 107.7.B.4
 5. PLEASE SHOW THE LOCATION AND ELECTRICAL REQUIREMENTS AND EQUIPMENT RELATED TO THE WASH STATIONS SHOWN ON SHEET #15...
 6. SHEET #7 SHOWS SEVERAL LIGHT POLES TO BE RELOCATED. WHERE ARE THESE POLES BEING RELOCATED TO? PLEASE SHOW THE ELECTRICAL REQUIREMENTS FOR THE RELOCATION...
 7. PLEASE SHOW THE EXISTING PARKING LOT LIGHTING IN THE AREAS ADJACENT TO THE TEMP BARN STRUCTURES TO INSURE THAT MINIMUM LIGHTING REQUIREMENTS ARE MET...CITY ORD. SEC 32-453(E)...
 8. PLEASE PROVIDE NEW ELECTRICAL SHEETS ADDRESSING THE COMMENTS...FBC 107.3.5

ELECTRICAL INSPECTOR **RND 2** CS NOT APPLICABLE
 COMMENTS: NO ELECTRICAL IS APPROVED AT THIS REVIEW PER BUILDING OFFICIAL //CS

AGENCY TOTALS: 1.25 9

CITY ENGINEERING ### REJECTED
 COMMENTS: Closed by revision 002 LROBERTS GM11110

CITY ENGINEERING LR REJECTED
 COMMENTS: owner recind review round. no engineer review required.

CITY ENGINEERING **RND 2** AJ NOT APPLICABLE
 COMMENTS: 1. Contractor must submit erosion and sedimentation agreement.

AGENCY TOTALS: 2.00 6

FIRE DEPARTMENT ### REJECTED
 COMMENTS: Closed by revision 004 LROBERTS GM11110

FIRE DEPARTMENT **RND 1** LW REJECTED
 COMMENTS: 9/13/13 1.00 0
 NFPA 241 (2004 Ed.) 8.7.2.3 - Where underground water mains and hydrants are to be provided, they shall be installed, completed and in service prior to construction work (no permit has been received for the new hydrants)
 NFPA 150 (2007 Ed.) 8.1.2.4.1 - In animal housing facilities not sprinklered . . . exit travel distance shall not exceed 75 feet from any point in the facility.

APP NBR ADDRESS
 Folio number

APPLICATION TYPE
 COUNTY FOLIO#

APP DATE OCC TYP VALUATION

NFPA 150 (2007 Ed.) 4.3.4 - Disaster/Emergency Management
 Program MUST BE IMPLEMENTED AND REVIEWED WITH FIRE
 DEPARTMENT (TRAINING).

FIRE DEPARTMENT **RND 2** LW APPROVED

9/23/13 1.00 10
 AGENCY TOTALS: 2.00 10

MECHANICAL INSPECTOR ### REJECTED

9/13/13 .00 0
 Closed by revision 007 LROBERTS GM11110

MECHANICAL INSPECTOR **RND 1** GCR NOT APPLICABLE

9/13/13 .25 0
 COMMENTS: NON-HABITABLE SPACE, MECHANICAL N/A.

MECHANICAL INSPECTOR **RND 2** GCR NOT APPLICABLE

9/23/13 .25 10
 COMMENTS: NON-HABITABLE SPACE, MECHANICAL N/A.

PLUMBING INSPECTOR ### REJECTED

9/12/13 .00 0
 Closed by revision 005 LROBERTS GM11110

PLUMBING INSPECTOR **RND 1** RPS REJECTED

9/12/13 .75 0
 COMMENTS: fbc admin 105.1 provide an application from a qualified
 plumbing contractor. Application should include the cost
 of the work.

fbc admin 107.2.1 Plans are code compliant but do not
 include any information on the temp. rest rooms.

PLUMBING INSPECTOR **RND 2** RPS NOT APPLICABLE

9/24/13 .25 12
 COMMENTS: all plumbing has been removed from plan at this time

AGENCY TOTALS: 1.00 12

ZONING OFFICIAL **RND 1** RCC APPROVED

9/12/13 .75 0
 9/20/13 .50 8

AGENCY TOTALS: 1.25 8

APPLICATION TOTALS: 11.25 70