FLORIDA DEPARTMENT OF HEALTH

Charlie Crist
Governor

Ana M. Viamonte Ros, MD, MPH
State Surgeon General

Broward County - MW
City of Hallandale Beach (PWS ID #4060573)
October 23, 2009

Hal Elsasser, WTP Chief Operator
City of Hallandale Beach
630 NW 2nd Street
Hallandale Beach, FL 33062

CITY OF HALLANDALE BCH
OPERATIONS
2009 NOV -9 PM 4:18

RE: Sanitary Survey

Dear Mr. Elsasser:

On September 10, 2009, Ewa Kudela-Leczynski, Engineer III, of the Broward County Health Department (BCHD) conducted a sanitary survey of the above-referenced public water system. A copy of the sanitary survey report is attached for your records. During this sanitary survey and a review of Department files, the following deficiencies were noted:

1. The discharge piping from each well pump did not have a smooth-nosed tap for sampling raw water.
2. Records were not available to document that Cross-Connection Control program has been established and implemented.

You may wish to consult your agent and/or engineer to address the above-referenced deficiencies. Please be aware that this letter does not supersede other Department correspondence, notification of deficiencies in other areas, enforcement action, etc.

The BCHD requests that you respond in writing within thirty (30) days of the date of this letter with the documentation that the deficiencies have been corrected or with the plan to correct them. You must take the appropriate corrective action no later than 120 days after notification, or be in compliance with a State-approved plan for correcting these deficiencies at the end of the same 120 day period.

If you have any questions regarding the sanitary survey, please contact **Ewa Kudela-Leczynski** at **(954) 467-4910** or via e-mail at ewa_leczynski@doh.state.fl.us .

Sincerely,

Phong D. Nguyen, P.E., MPA
Assistant Environmental Engineering Director

PN/EKL

Attachments