

**DEVELOPMENT SERVICES- BUILDING DIVISION
NIGHTCLUB INSPECTIONS REPORT
FY 2014-2015(MECHANICAL)**

EXHIBIT 6

DATE/TIME	LOCATION/ADDRESS	RESULT	COMMENTS
6/2/2014 1.25HR	CHAPULTEPEC MEXICAN BAR & RESTAURANT 23 N.W. 2 ND AVE	Approved	
5/30/2014 1.25Hr	TATIANA 1710 E. HALLANDALE BEACH BLVD.	Approved	Column1
6/2/2014 2Hrs	FLANNIGAN'S SEAFOOD BAR AND GRILL 4. N. FEDERAL HIGHWAY	Denied	Column1 6/5/14 Ove in kitchen area use for cooking chicken and bacon shall be under type one hood.FBCM 507.2.1
6/24/2014 2 Hrs	GULFSTREAM PARK FOOD & BEVERAGE 901 S. FEDERAL HIGHWAY	Denied	Column1 Relocate appliances under kitchen hoods. FBCM 507.2.1 6/5/2014 Areas 1. Finish line dell. 2. North side food court. 3. First floor kitchen north side. 4.Riders up 2 floor kitchen, relocate refrigerator from hood area.
6/4/2014 1.25Hr	HOLLYWOOD CONCESSIONS, INC/Mardi Gras 831 N. FEDERAL HIGHWAY	Approved	Column1
6/2/2014 1.Hr	OCEAN'S 11 LOUNGE SOUTH 800 N. FEDERAL HIGHWAY	Column1 Approved	Column2 Column3

**DEVELOPMENT SERVICES- BUILDING DIVISION
NIGHTCLUB INSPECTIONS REPORT
FY 2014-2015(MECHANICAL)**

DATE/TIME	LOCATION/ADDRESS	RESULT	Column1
6/2/2014 1.5 Hr	UPPERDECK PROPERTIES 906 E HALLANDALE BLVD	Approved 6/5/2014	
6/4/2014 2Hr	GULFSTREAM PK RACING ASSOC 601 SILKS RUN Suite 2499	Approved 6/6/2014	Column1
6/4/2014 1Hr	FATE NO ACCESS		
6/4/2014 1Hr	GULFSTREAM PK RACING ASSOC MARTINI BAR 601 SILKS RUN Suite 2497	Approved	Column1
6/4/2014 1Hr	ADENA 900 SILKS RUN Bldg 1700	Denied	Column1 Restaurant is still under construction. CO must be obtained before opening for business

Night Club after hours Inspection Report

PLUMBING

Location Name & address	Pass/fail	Comments
	pass	Health dept. inspection received
<i>Chapultepec Mexican Bar & Rest</i>	failure	1. Grease interceptor pumping information not received
23 NW 2 Ave		2.
		3.
		4.
		5.
		6.
		7.
		8.
		9.
		10.

Location Name & address	Pass/fail	Comments
	pass	1. Health dept. inspection received
<i>Fate Night Club</i>		2. Grease trap pumping information received
601 Silks Run #2499		3.
		4.
		5.
		6.
		7.
		8.
		9.
		10.
		11.

Location Name & address	Pass/fail	Comments
	pass	1. Health dept. inspection received
<i>FL Tatiana Club-Restaurant</i>	pass	2. Grease trap pumping information received
1710 E Hallandale Bch Blvd	failure	3. Ice maker & coffee machine need back flows
	failure	4. Wheeled Gas appliances require restraints
		5.
		6.
		7.
		8.
		9.
		10.

Location Name & address	Pass/fail	Comments
		11.
	pass	1. Health dept. inspection received
<i>Flannigan's Seafood Bar & Grill</i>	pass	2. Grease trap pumping information received
4 N Federal Hwy		3.
		4.
		5.
		6.
		7.
		8.
		9.
		10.
		11.

Location Name & address	Pass/fail	Comments
	pass	1. Health dept. inspection received
<i>Martini Bar</i>	fail	2. Grease trap pumping report not recieved
605 Silks Run #2491		3.
		4.
		5.
		6.
		7.
		8.
		9.
		10.
		11.

Location Name & address	fail	Comments
	required	1. Health Dep. reports
<i>Orchid Concessions, Inc.</i>	required	2. Grease Trap maintenance reports
(Gulfstream Park)	required	3. Ten Palms/wheeled gas appliance restraints
901 S Federal Hwy	required	4. 1 ST floor kit ,back flow {ice}& restraints on gas appl.
	required	5. Finish line needs back flow for ice maker
	required	6. Simo Cast North Side Deli req. back flow at carbonation, coffee machine req. back flow.
	required	7. Riders Up/ Back flow at ice machine
	required	8. Outside Bar /kitchen{Stretch} gas appliance restraints and ice maker back flow
		9.
		10.
		11.

Location Name & address	Pass/fail	Comments
	pass	1. Health dept. inspection received/ all {5}
<i>Hollywood Concessions</i>	pass	2. Grease trap pumping report received
(Mardi Gras Casino)		3.
831 N Federal Hwy		4.
		5.
		6.
		7.
		8.
		9.
		10.
		11.

Location Name & address	Pass/fail	Comments
	pass	1. Health dept. inspection received
<i>Oceans 11 Lounge</i>	fail	2. Grease trap pumping information not received
800 N Federal Hwy		3.
		4.
		5.
		6.
		7.
		8.
		9.
		10.
		11.

Location Name & address	Pass/fail	Comments
	pass	1. Health dept. inspection received
<i>Upper Deck</i>	pass	2. Grease trap pumping report received
906 E Hallandale Bch Blvd		3.
		4.
		5.
		6.
		7.
		8.
		9.
		10.
		11.

Location Name & address	Pass/fail	Comments
		1.
<i>The Cheetah</i>		2. Jan. 2015
100 Ansin Blvd		3.
		4.
		5.
		6.
		7.
		8.
		9.
		10.
		11.

Night Club after hours Inspection Report

Electrical

Location Name & address	Pass/fail	Comments
		1.
<i>Chapultepec Mexican Bar & Rest</i>	<i>Pass</i>	2.
23 NW 2 Ave		3.
		4.
		5.
Date: 6/9/14		6.
POC: CARLA NUNEZ		7.
305-494-6884		8.
		9.
		10.
		11.

Location Name & address	Pass/fail	Comments
		1.
<i>Fate Night Club</i>	<i>Pass</i>	2.
601 Silks Run #2499		3.
		4.
		5.
Date: 6/9/14		6.
POC: RAMSI NABOR		7.
248-787-3881		8.
		9.
		10.
		11.

Location Name & address	Pass/fail	Comments
		1. Must repair two exit lights @ SW rear exit door
<i>FL Tatiana Club-Restaurant</i>	<i>Fail</i>	2. Provide covers on receptacles at mezzanine above stage behind amp rack.
1710 E Hallandale Bch Blvd		3. Repair lt at mezzanine above stage.
		4.
		5.
Date: 6/4/14		6.
POC:		7.
		8.
		9.
		10.
		11.

Location Name & address	Pass/fail	Comments
		1.
<i>Flanigans Seafood Bar & Grill</i>	<i>Pass</i>	2.
4 N Federal Hwy		3.
		4.
		5.
Date: 6/5/14		6.
POC:		7.
		8.
		9.
		10.
		11.

Location Name & address	Pass/fail	Comments
		1. NO ACCESS, WENT BY NUMEROUS TIMES
<i>Martini Bar</i>	<i>FAIL</i>	2.
605 Silks Run #2491		3.
		4.
		5.
DATE:		6.
POC:		7.
		8.
		9.
		10.
		11.

Location Name & address	Pass/fail	Comments
		1. Remove ext cord next to ice cream case (Riders Cup)
<i>Orchid Concessions, Inc</i>	<i>FAIL</i>	2. Exposed wires @ ceiling in Ten Palms N. prep kitchen
(Gulfstream Park)		3. Exit light inop @ Ten Palms N. prep kitchen
901 S Federal Hwy		4. Exit It in main production kitchen inop
		5. 1 st Fl kitchen L/V wiring hanging down from ceiling @ several areas.
		6. Remove all extension cords from finish line concession/deli.
Date: 6/5/14		7. Remove cord from inside ceiling area @ N. side deli for all signs.
POC: DANNEAN MALAVE		8. Tiki/stretches kitchen exit Its inop.
954-242-2771		9. Remove extension cords from stretches tiki umbrellas.
		10.
		11.

Location Name & address	Pass/fail	Comments
		1.
<i>Hollywood Concessions</i>	PASS	2.
(Mardi Gras Casino)		3.
831 N Federal Hwy		4.
		5.
		6.
DATE: 6/9/14		7.
POC: BRIAN CLARK		8.
954-347-5231		9.
		10.
		11.

Location Name & address	Pass/fail	Comments
		1. Remove exit sign from door not considered exit @ patio.
<i>Oceans 11 Lounge</i>	FAIL	2. Provide an exit lt @ kitchen over door & another in hallway just outside of kitchen.
800 N Federal Hwy		3.
		4.
		5.
		6.
DATE: 6/9/14		7.
POC: REKHA RAYO		8.
954-454-5858		9.
		10.
		11.

Location Name & address	Pass/fail	Comments
		1.
<i>Upper Deck</i>	Pass	2.
906 E Hallandale Bch Blvd		3.
		4.
		5.
DATE: 6/9/14		6.
POC:		7.
		8.
		9.
		10.
		11.

Location Name & address	Pass/fail	Comments
		1.
<i>The Cheetah</i>		2.
100 Ansin Blvd		3.
		4.
		5.
DATE:		6.
POC:		7.
		8.
		9.
		10.
		11.

Night Club after hours Inspection Report

Structural

Location Name & address	Pass/fail	Comments
		1.
<i>Chapultepec Mexican Bar & Rest</i>	P	2. 6/4/14 Occupant load not posted.
23 NW 2 Ave		3.
		4. 6/10/14 Re-inspection, occupant load posted at the back bar area, phone conversation with owner occupant load should be posted by front door.
		5.
		6.
		7.
		8.
		9.
		10.
		11.

Location Name & address	Pass/fail	Comments
		1.
<i>Fate Night Club</i>	P	2. 6/6/14 No issues.
601 Silks Run #2499		3.
		4.
		5.
		6.
		7.
		8.
		9.
		10.
		11.

Location Name & address	Pass/fail	Comments
		1.
<i>FL Tatiana Club-Restaurant</i>	F	2. 6/6/14 Clear storage from exit corridors. Move max. cop. Sign to front door. Verify balcony railing height.
1710 E Hallandale Bch Blvd		3.
		4. 6/9/14 Restaurant Manager provided letter stating, the exits are completely clear during operation hours.
		5.
		6.

		7.
		8.
		9.
		10.
		11.
Location Name & address	Pass/fail	Comments
		1.
<i>Flanigans Seafood Bar & Grill</i> 4 N Federal Hwy	P	2. 6/4/14 Permit 13-3027 issued as outdoors waiting area.
		3.
		4.
		5.
		6.
		7.
		8.
		9.
		10.

Location Name & address	Pass/fail	Comments
		1.
<i>Martini Bar</i> 605 Silks Run #2491	P	2. 6/6/14 No issues.
		3.
		4.
		5.
		6.
		7.
		8.
		9.
		10.
		11.

Location Name & address	Pass/fail	Comments
		1.
<i>Orchid Concessions, Inc</i> (Gulfstream Park) 901 S Federal Hwy	P	2. 6/6/14 No issues.
		3.
		4.
		5.
		6.
		7.
		8.
		9.

		10.
		11.

Location Name & address	Pass/fail	Comments
		1.
<i>Hollywood Concessions</i>	P	2. 6/6/14 No issues.
(Mardi Gras Casino)		3.
831 N Federal Hwy		4.
		5.
		6.
		7.
		8.
		9.
		10.
		11.

Location Name & address	Pass/fail	Comments
		1.
<i>Oceans 11 Lounge</i>	P	2. 6/9/14 No issues.
800 N Federal Hwy		3.
		4.
		5.
		6.
		7.
		8.
		9.
		10.
		11.

Location Name & address	Pass/fail	Comments
		1.
<i>Upper Deck</i>	F	2. 6/4/14 Means of egress from office/mezzanine, clear all boxes & tool box from stairs.
906 E Hallandale Bch Blvd		3.
		4. 6/10/14 Re-inspection, means of egress from office/mezzanine, boxes & tool box stored at stairs blocking the required clear width of the stairs. Verbally told Costas that the stairs must remain

		clear. A re-inspection will be done within 7 days.
		5.
		6.
		7.
		8.
		9.
		10.
		11.

Location Name & address	Pass/fail	Comments
		1.
<i>The Cheetah</i>		2. No inspection done
100 Ansin Blvd		3. For consideration in January 2015
		4.
		5.
		6.
		7.
		8.
		9.
		10.
		11.

Location Name & address	Pass/fail	Comments
		1.
<i>Adena Grill</i>		2. No inspection done
901 Silks Run		3. Construction in progress. CO must be obtained prior to opening for business.
		4.
		5.
		6.
		7.
		8.
		9.
		10.
		11.



TATIANA RESTAURANT & NIGHT CLUB
1710 EAST HALLANDALE BEACH BLVD.
HALLANDALE BEACH, FL 33009

To Whom It May Concern :

This letter is to confirm that the chairs and tables are removed from exits . The restaurant exits are completely clear during the operation hours.

If you have any further questions please feel free to contact.

Sincerely,

Grazina Pilkaitiene

General Manager

June 9, 2014

Phone # (954) 454-1222

Fax # (954) 454-1274

E-mail: tatiana_restaurant@yahoo.com