



HALLANDALE BEACH FIRE RESCUE
 Division of Fire Prevention and Public Education
 121 S.W. 3rd Street
 Hallandale Beach, Florida 33009
 FAX: (954) 457-1472

<u>Contact Us</u>	
Division Chief G. Pagliarulo gpagliariulo@cohb.org	(954) 457-1477
Fire Marshal M. Aleman maleman@cohb.org	(954) 457-1478
Fire Inspector L. Williams lwilliams@cohb.org	(954) 457-1478
Fire Inspector Y. Feijoo yfeijoo@cohb.org	(954) 457-3051

FIRE INSPECTION REPORT

ANNUAL - Commercial (0-5000) Assigned To ALEMAN, Miguel on 4/29/2014

Date: 4/29/2014 9:18:32AM

Location Number: 411280

Business Name: CHEETAH

Address: 100 ANSIN BLVD

City/State/Zip: HALLANDALE BEACH, FL 33009

Violations

Standard/Reference

GENERAL

SPECIAL HAZARD

PROVIDE INFORMATION ON 'BOTTLE SERVICE' SPARKLERS.

06-03-2013

04-28-2014

FIRE ALARM

ALARM PANEL SHOWS TROUBLE - SERVICE

SYSTEM DEFECTS OR MALFUNCTIONS SHALL BE CORRECTED IMMEDIATELY.

12/09/2013 FIRE ALARM IN TROUBLE

04-28-2014 DIALER IN TROUBLE

GENERAL

PRIOR VIOLATIONS NOT CORRECTED

02/19/2014 OCCUPATIONAL LICENSE

GENERATOR

PROVIDE / MAINTAIN GENERATOR MAINT. LOG

ELECTRICAL

BREAKER BOX NEEDS FILLER BLANKS

HOOD SYSTEMS

HOOD SYSTEM OVERDUE FOR SERVICE

HOOD SUPPRESSION SYSTEMS MUST BE SERVICED EVERY SIX MONTHS AND TAGGED.

EGRESS / EXIT

EXITS OBSTRUCTED, LOCKED OR DAMAGED

DOORS SHALL BE ARRANGED TO BE OPENED READILY FROM THE EGRESS SIDE WHENEVER THE BUILDING IS OCCUPIED, PENALTY APPLIED FOR BLOCKED EXITS UNDER P1.

EXIT SIGNS MUST BE LIT AT ALL TIMES

EVERY EXIT SIGN SHALL BE ILLUMINATED DURING NORMAL AND EMERGENCY OPERATION. NOTIFY INSPECTOR IF LIGHTING SYSTEMS ARE ON TIMERS FROM DUSK TO DAWN OPERATION.

HAZMAT

CYLINDERS NEED CAP / CHAIN - MUST SECURE

ANNUAL - Commercial (0-5000) Assigned To ALEMAN, Miguel on 4/29/2014

Date: 4/29/2014 9:18:32AM

Location Number: 411280

Business Name: CHEETAH

Address: 100 ANSIN BLVD

City/State/Zip: HALLANDALE BEACH, FL 33009

Recipient Signature

Recipient:



HALLANDALE BEACH FIRE RESCUE
Division of Fire Prevention and Public Education
121 S.W. 3rd Street
Hallandale Beach, Florida 33009
FAX: (954) 457-1472

<u>Contact Us</u>	
Division Chief G. Pagliarulo	(954) 457-1477
gpagliariulo@cohb.org	
Fire Marshal M. Aleman	(954) 457-1479
maleman@cohb.org	
Fire Inspector L. Williams	(954) 457-1478
lwilliams@cohb.org	
Fire Inspector Y. Feljoo	(954) 457-3051
yfeljoo@cohb.org	

FIRE INSPECTION REPORT

REINSPECTION Assigned To ALEMAN, Miguel on 5/8/2014

Date: 5/8/2014 8:15:55AM

Location Number: 411280

Business Name: CHEETAH

Address: 100 ANSIN BLVD

City/State/Zip: HALLANDALE BEACH, FL 33009

Violations

Standard/Reference

GENERAL

SPECIAL HAZARD

PROVIDE INFORMATION ON 'BOTTLE SERVICE' SPARKLERS.

06-03-2013

04-28-2014

FIRE ALARM

ALARM PANEL SHOWS TROUBLE - SERVICE

SYSTEM DEFECTS OR MALFUNCTIONS SHALL BE CORRECTED IMMEDIATELY.

12/09/2013 FIRE ALARM IN TROUBLE

04-28-2014 DIALER IN TROUBLE

05-06-2014 DIALER IN TROUBLE- COMPANY IN PROCESS OF REPLACING PHONE LINE TO FIBER OPTICS. ESTIMATED TIME OF COMPLETION 1 WEEK.

GENERAL

PRIOR VIOLATIONS NOT CORRECTED

02/19/2014 OCCUPATIONAL LICENSE

GENERATOR

PROVIDE / MAINTAIN GENERATOR MAINT. LOG

ELECTRICAL

BREAKER BOX NEEDS FILLER BLANKS

HOOD SYSTEMS

HOOD SYSTEM OVERDUE FOR SERVICE

HOOD SUPPRESSION SYSTEMS MUST BE SERVICED EVERY SIX MONTHS AND TAGGED.

EGRESS / EXIT

EXITS OBSTRUCTED, LOCKED OR DAMAGED

DOORS SHALL BE ARRANGED TO BE OPENED READILY FROM THE EGRESS SIDE WHENEVER THE BUILDING IS OCCUPIED. PENALTY APPLIED FOR BLOCKED EXITS UNDER P1.

EXIT SIGNS MUST BE LIT AT ALL TIMES

EVERY EXIT SIGN SHALL BE ILLUMINATED DURING NORMAL AND EMERGENCY OPERATION. NOTIFY INSPECTOR IF LIGHTING SYSTEMS ARE ON TIMERS FROM DUSK TO DAWN OPERATION.

HAZMAT

CYLINDERS NEED CAP / CHAIN - MUST SECURE

REINSPECTION Assigned To ALEMAN, Miguel on 5/8/2014

Date: 5/8/2014 8:15:55AM

Location Number: 411280

Business Name: CHEETAH

Address: 100 ANSIN BLVD

City/State/Zip: HALLANDALE BEACH, FL 33009

Recipient Signature

Recipient:



HALLANDALE BEACH FIRE RESCUE
Division of Fire Prevention and Public Education
121 S.W. 3rd Street
Hallandale Beach, Florida 33009
FAX: (954) 457-1472

<u>Contact Us</u>	
Division Chief G. Pagliarulo	(954) 457-1477
gpagliariulo@cohb.org	
Fire Marshal M. Aleman	(954) 457-1479
maleman@cohb.org	
Fire Inspector L. Williams	(954) 457-1478
lwilliams@cohb.org	
Fire Inspector Y. Feljoo	(954) 457-3051
yfeljoo@cohb.org	

FIRE INSPECTION REPORT

REINSPECTION - Correction Card Submitted Assigned To WILLIAMS, Lori on 6/6/2014

Date: 6/6/2014 4:55:43PM

Location Number: 411280

Business Name: CHEETAH

Address: 100 ANSIN BLVD

City/State/Zip: HALLANDALE BEACH, FL 33009

GENERAL

NO FIRE CODE VIOLATIONS NOTED

NO FIRE CODE VIOLATIONS WERE NOTED DURING THE LISTED INSPECTION. INSPECTION WAS SATISFACTORY.

Recipient Signature

Recipient:



HALLANDALE BEACH FIRE RESCUE
Division of Fire Prevention and Public Education
121 S.W. 3rd Street
Hallandale Beach, Florida 33009
FAX: (954) 457-1472

FIRE INSPECTION REPORT

Contact Us

Division Chief L. Williams	(954) 457-1478
lwilliams@cohb.org	
Fire Marshal M. Aleman	(954) 457-1479
maleman@cohb.org	
Fire Inspector Y. Feijoo	(954) 457-3051
yfeijoo@cohb.org	
Fire Inspector O. Hurtado	(954) 457-1477
ohurtado@cohb.org	
Fire Inspector J. Kupkovich	(954) 457-1470
jkupkovich@cohb.org	

Date: 7/28/2014 12:00:00AM

Location Number: 411280

Business Name: CHEETAH

Address: 100 ANSIN BLVD

City/State/Zip: HALLANDALE BEACH, FL 33009

Violations

Standard/Reference

EGRESS / EXIT

EXITS OBSTRUCTED, LOCKED OR DAMAGED

DOORS SHALL BE ARRANGED TO BE OPENED READILY FROM THE EGRESS SIDE WHENEVER THE BUILDING IS OCCUPIED. PENALTY APPLIED FOR BLOCKED EXITS UNDER P1.

07/28/2014 TENANT AT 1054 NW 1 CT CALLED TO COMPLAIN ABOUT OBSTRUCTION OF REAR EXIT DOOR FENCE WITHOUT PERMIT. SPOKE WITH GREG GARMON GENERAL MANAGER AND REQUESTED FOR THE FENCE TO BE REMOVED IMMEDIATELY .

PENALTIES

BLOCKED EXIT PENALTY

FIRST OFFENSE - REMOVE ALL BARRIERS, IMPROPER LOCKING DEVICES, OR OBSTRUCTIONS FROM DESIGNATED EXITS.

09/08/2014 SECOND REQUEST TO REMOVED FENCE FROM THE REAR EXIT 1054 NW 1 CT. UNDER CITY ORDINANCE THERE IS A \$250 FINE. YOU HAVE 24 HRS TO BE IN COMPLIANCE.

Recipient Signature

Recipient:
