



Hallandale Beach
PROGRESS. INNOVATION. OPPORTUNITY.

ADDENDUM # 3

BID # FY 2017-2018-015

CITY OF HALLANDALE BEACH PURCHASE OF SEWER LIFT STATIONS PUMPS

Please ensure you check the City's website for the latest addendum released for this project. Below find the link to the City's website: www.cohb.org/solicitations.

Firm must provide this form signed by an authorized officer of your Firm to acknowledge receipt of ADDENDUM # 3 and provide with your Firm's response.

PLEASE NOTE:

Correction to Exhibit A – Technical Pump Specifications, Manufacturer (2) – KSB, page 6, Equipment Tests.

CHANGE FROM: EXHIBIT A – TECHNICAL PUMP SPECIFICATIONS, MANUFACTURER (2) – KSB, PAGE 6, EQUIPMENT TESTS:

Equipment Tests - Tests shall be performed in accordance with the Test Code for Centrifugal Pumps per the Standards of the Hydraulic Institute, Level A. Tests shall be performed on the actual assembled pumps to be supplied. Tests shall cover a range from shut-off to a minimum 20% beyond specified design capacity. Conduct test per above specification on all supplied pumps, generating a curve showing actual flow, head, BHP and hydraulic efficiency.

CHANGE TO: EXHIBIT A – TECHNICAL PUMP SPECIFICATIONS, MANUFACTURER (2) – KSB, PAGE 6, EQUIPMENT TESTS:

Equipment Tests - Pumps tested and certified at latest ISO Standards are acceptable.

PLEASE NOTE RECEIPT OF ADDENDUM # 3 BY SIGNING BELOW AND INCLUDE WITH YOUR FIRM'S SUBMISSION.

I ACKNOWLEDGE RECEIPT OF ADDENDUM # 3:

Company	
Name	
Title	
Signature	
Date	

Sincerely,



Andrea Lues, Director, Procurement Department

DRAFT TO BE ANSWERED BY PROJECT MANAGER